Hitelecom®

Industrial-site Camera H100-HTC1800

Define the view.
Specify the image.



KEY INDICATORS

Reference model	Viewing task	Optical brief	Integration	Project delivery
H100-HTC1800	Scene & image detail	Coverage & lighting	Viewing & recording	Validation & records
Dome-camera visual	Project-defined	Agreed configuration	Agreed system path	Written specification

OVERVIEW

Use the Hitelecom H100-HTC1800 dome-camera reference as a starting point for industrial-site visual monitoring. Develop the configuration around the scene, observation distance, lighting, installation conditions and receiving system. Agree the optics, imaging, power and connection requirements, then validate the proposed configuration against representative site conditions.

CUSTOMIZATION FOCUS

Observation task

Define what the operator needs to see, the target location and the decisions the view should support.

Coverage & placement

Review the viewing distance, mounting position, scene boundaries and likely obstructions before selecting the lens.

Lighting conditions

Review normal and low-light scenes, backlight, reflections and any permitted illumination requirements.

Image & motion needs

Agree useful image detail, motion conditions and frame-rate requirements against representative scene samples.

Installation scope

Define power, cabling, mounting access, environmental exposure and any required product qualification.

System integration

Specify the viewing, recording and access workflow, then verify the agreed camera and receiving-system configuration.

APPLICATIONS


Manufacturing & Workshops


Warehouses & Logistics


Entrances & Shared Areas


Plant Rooms & Utilities


Energy & Remote Sites


Water & Environmental Sites


Labs & Controlled Areas


Transport & Site Services

Representative scenes. Eight areas cover 40 website observation tasks; these are not camera samples, customer installations or verified performance claims.

Item		Description
Identity	Model	H100-HTC1800, as named for the supplied product reference.
	Product visual	Hitelecom dome-camera form shown in the original supplied image. The visual does not define imaging or electrical parameters.
	Document status	Reference / Project Configuration. The agreed product specification defines the delivered version.
Imaging	Observation brief	Define the target, viewing distance, required image detail, scene boundaries and normal operating conditions.
	Lens and coverage	Agree lens selection, field of view, focus arrangement and mounting geometry for the project.
	Image and motion	Agree the sensor, resolution, image settings, frame rate and motion requirements through the configuration proposal and scene validation.
	Lighting	Assess illumination, backlight and reflections. Define any low-light or additional illumination requirement in the agreed scope.

No fixed resolution, lens, sensor, frame-rate or illumination specification has been provided for this reference. Do not infer resolution or viewing angle from the model suffix.

DEPLOYMENT & OPERATING DETAILS


Item		Description
Power	Supply and interfaces	Agree power source, electrical limits, cable interfaces, connection method and the approved wiring instructions.
System	Viewing and recording	Define the receiving system, supported data path, recording location, retention and operator access requirements.
	Compatibility	Confirm the exact camera version and receiving-system functions. Include requested protocols or software integration in the proposal.
	Software scope	Identify any required integration work and document the functions included in the delivered project.
Site	Mounting and environment	Specify mounting, service access, temperature, moisture, dust, cleaning and any enclosure or destination requirements.
	Qualification evidence	Agree any required ingress, impact, EMC, safety or sector-specific evidence for the supplied configuration.
Project	Design approval	Record the selected hardware, imaging parameters, electrical and interface definition, product identification and any software scope.
	Acceptance	Agree scene trials, required image detail, lighting conditions, connection checks and the supplied configuration record.
	Delivery documents	Approved configuration record, installation instructions, test evidence and maintenance information within the agreed supply scope.

This reference does not establish analytics, automatic recognition, infrared illumination, pan/tilt/zoom, thermal imaging, audio, network protocols or a particular power/communications interface.

Confirm all requested functions and any environmental or sector approvals in the supplied model-specific documents. Visual monitoring is not a substitute for process instruments, machine safeguarding or emergency protection.

Agree recording, access control and any personal-data handling with the site operator and receiving-system integrator. The product image is not a performance demonstration.

VISUAL MONITORING WORKFLOW



Illustrative project workflow. Define the observation task, camera configuration and receiving-system responsibilities, then validate the agreed arrangement with representative scenes.

Tel: +86 18616602589 / Web: www.hitelecom.com

Email: sales@hitelecom.cn

Add: 2nd Floor, Building 1, No. 116 Cheyang Road,
Songjiang District, Shanghai, China